



Consumer Environmental Health
 841 North Broadway, Room 304
 Milwaukee, WI 53202

Phone 414.286.3674
 Fax 414.286.5164
 www.milwaukee.gov

Food Inspection

Routine Inspection

June 05, 2007

ROBERT PYLES, BETTY PYLES
 MCDONALD'S
 8100 W BROWN DEER RD
 MILWAUKEE, WI 53223

The following list of violations of the Wisconsin Administrative Code as adopted by reference in the Milwaukee Code of Ordinances Chapter 68, and/or other City ordinance(s) must be corrected as soon as possible but not later than the date specified. A re-inspection fee may be assessed if the violation is not corrected by that date. An inspection fee may be charged for any repeat violations.

Code Number	Description of Violation	Correct By
3-301.11	Move the towel dispenser to the right side of the the four compartment sink. The far right sink basin is the only sink that can be used for hand washing. By locating the towel dispenser near the soap, employees will remember that the far right sink is the dirty sink.	06/05/2007
5-202.13	No air gap installed for the ice machine on the front counter. Install an air gap for the ice machine drain. The ice machine drainage in the back is tied to the drain funnel causing the drain to have no air gap. Ensure that there is an air gap at the ice machine drain in the back.	06/19/2007
5-205.11	Men's restroom has no warm water going to the autmatic sink. Provide and ensure that warm water is dispensed from the automatic sink.	06/05/2007
4-501.114	The setup of the ware wash sink was wrong. The far right sink needs to be empty for scraping and handwashing, the 2nd sink from the left is for detergent, the 3rd sink is for rinsing in clean water, and the far left sink is for sanitizing. Ensure that all employees understand the proper ware wash setup.	06/05/2007
5-205.15	Drainage in the cabinet underneath the orange juice machine is no longer in use. It needs to be properly capped off or sealed to prevent exposure to methane gas. The employee restroom is also no longer in use. It will also have to be properly abandoned to prevent possible exposure to methane gas.	06/05/2007

No NonStandard Violations to Report

Think Health Act Now!
CITY OF MILWAUKEE HEALTH DEPARTMENT

Consumer Environmental Health
841 North Broadway, Room 304
Milwaukee, WI 53202


Phone 414.286.3674
Fax 414.286.5164
www.milwaukee.gov

Inspection Note:

Notes: Provide a tray for the ice scoop in the back by the ice machine.

Please be advised that this document is subject to public review under open records law. - Wis. Statutes section 19.35(1)(a)

Inspector Signature



Operator Signature

