



Tom Barrett
Mayor

Bevan K. Baker, FACHE
Commissioner of Health

Raquel M. Filmanowicz
Health Operations Administrator

Health Department

Family and Community Health Services

web site: www.milwaukee.gov/health

Routine Food

Bon Appetit Management Co.
Kohl's Lake Park
7800 N 113th St
Milwaukee, WI

6/10/2011

The following list of violations of the Wisconsin Administrative Code as adopted by reference in the Milwaukee Code of Ordinances Chapter 68, and/or other City ordinance(s) must be corrected as soon as possible but not later than the date specified. A re-inspection fee may be assessed if the violation is not corrected by that date. An inspection fee may be charged for any repeat violations.

Code Number	Description of Violation	Correct By
	No Violations to Report	

Notes:

Establishment has met requirements for Health Department hold to be released.

The following items are to be completed by Friday June 17th.

- 1) The air gap at the food prep sink must be adjusted to provide adequate clearance to the drain. This must comply with the State Uniform Plumbing Code, chs. Comm 81-87, as enforced by the Wisconsin Department of Commerce. (5-202.13)
- 2) The adjustment to the 4 compartment sink has been approved by Kevin Hulbert. This must be completed by above date.
- 3) Provide: stem thermometers, sanitizer, and sanitizer test strips.

On 6/10/2011, I served these orders upon Bon Appetit Management Co. by leaving this report with

Inspector Signature (Inspector ID:82)

Operator Signature