



Tom Barrett
Mayor

Bevan K. Baker, FACHE
Commissioner of Health

Raquel M. Filmanowicz
Health Operations Administrator

Family and Community Health Services

Health Department

web site: www.milwaukee.gov/health

Routine Food

VINCENT HIGH SCHOOL
VINCENT HIGH SCHOOL
7501 N GRANVILLE RD
MILWAUKEE, WI

5/12/2008

The following list of violations of the Wisconsin Administrative Code as adopted by reference in the Milwaukee Code of Ordinances Chapter 68, and/or other City ordinance(s) must be corrected as soon as possible but not later than the date specified. A re-inspection fee may be assessed if the violation is not corrected by that date. An inspection fee may be charged for any repeat violations.

Code Number	Description of Violation	Correct By
	No Violations to Report	

Notes:

Clean the slicer thoroughly after using.

Recommendations: Install an "add a faucet" at the sprayer arm of the ware wash sinks. This will facilitate and promote hand washing.

The waste drains at the 2 compartment sink being used for washing vegetables and fruits are not air gapped. All food preparation sinks are required to be air gapped. Have the 2 compartment sink waste drains properly air gapped by a licensed plumber.

On 5/12/2008, I served these orders upon VINCENT HIGH SCHOOL by leaving this report with

Inspector Signature (Inspector ID:66)

Operator Signature